# Intrinsically Safe Pressure Transmitter for highest pressure applications in hazardous environments Model IS-20-H





### Applications

- Chemical and petro chemical industry
- Polyethylene production plants

### **Special Features**

- Pressure ranges from 0 ... 1600 bar to 0 ... 6000 bar
- Sensor stayed via sealing cone
- Ex- protection Ex ia I/II C T6 in compliance with ATEX: Gases, vapours and mist: Zone 0, Zone 1 and Zone 2
- FM, CSA approval for
  - Intrinsic safe Class I, II and III Division 1, Group A, B, C, D, E, F, G
  - Dust Class II and III Division 1, Group E, F, G
  - Class I, Zone 0, AEx ia II C



Fig. left: IS-20-H with L-connector Fig. right: IS-20-H with fieldcase

## Description

#### **Global explosion protection**

These pressure transmitters meet approvals such as ATEX, FM, CSA, which are relevant throughout the world. All data required in connection with the approval is included on the product label. The globality of the product is thus given special emphasis.

#### Structure

All wetted parts materials are specially suited for extremely high pressure ranges. The rugged case is made of stainless steel and provides at least IP 65 ingress protection (special versions up to IP 67).

The transmitters are supplied via appropriate intrinsically safe line transformers, or via typical zener diode barriers with an input power of 10 ... 30 V. The output signal is 4 ... 20 mA, 2-wire.

#### High permanent load stability

Due to the specially clamped sensor element a high stability to permanent load cycles is achieved even in highly dynamic processes. Furthermore, the well-proven WIKA technology guarantees high accuracy and longterm stability of the pressure transmitters.

As several pressure and electrical connections are possible, the user can find the optimal solution for his measuring task.

This product is a combination of the excellent approvalrelevant features of the intrinsically safe pressure transmitter and superior high pressure characteristics.

WIKA Data Sheet PE 81.51 · 09/2008

Data Sheets for related models: Intrinsically Safe Pressure Transmitter for highest pressure applications; model HP-2; see data sheet PE 81.53 WIKA

Part of your business

Page 1 of 6

WIKA Data Sheet PE 81.51

# Specifications

# Model IS-20-H

S	pecifications	without	model	designation	apply	for all	models.	
-	peointoutions	minour	model	acoignation	uppiy	ioi un	modelo	

Specifications without model desi	gnation apply fo	r all models.				
Pressure ranges	bar	1600	2500	4000	5000	6000
Over pressure safety	bar	2300	3500	5000	6000	7000
Burst pressure	bar	4000	6000	8000	10000	11000
Materials						
Wetted part		Stainless steel				
Case		Stainless steel				
Power supply U <sub>B</sub>	U <sub>B</sub> in VDC					
» Model IS-20-H		10 30				
» Model IS-20-H with fieldcase		11 30				
Signal output and		4 20 mA, 2-	wire			
maximum ohmic load RA	R <sub>A</sub> in Ohm					
» Model IS-20-H		R <sub>A</sub> ≤ (U <sub>B</sub> – 10 <sup>1</sup>	V) / 0.02 A - (leng	gth of flying lea	ds in m x 0.14 Of	ım)
» Model IS-20-H with fieldcase		R <sub>A</sub> ≤ (U <sub>B</sub> – 11 )				
Test circuit signal / max. load RA		R <sub>A</sub> ≤ 15 Ohm (	only model IS-20	D-H with fieldca	ase)	
Adjustability zero/span	%		ntiometers inside			
Response time (10 90 %)	ms	≤1				
Power Pi	W		h approval for Ca	ategory 1D)		
Insulation voltage			plies with EN 60			
Accuracy	%	≤ 0.25	(BFSL)			
	% of span	$\leq 0.5^{1}$	(2:02)			
			esis, zero point a	and full scale e	rror (corresponds	to error of
		it per IEC 61298				
		vertical mounting	,	wer pressure of	onnection	
Non-linearity	% of span	≤ 0.2	•	ording to IEC 6		
Non-repeatability	% of span	≤ 0.1			1290-2	
1-year stability	% of span	≤ 0.1 ≤ 0.2	(at reference	e conditions)		
Permissible temperature of	70 01 Span	<u> </u>	(at reference	e conditions)		
■ Medium <sup>2) 4)</sup>		-20 +80 °C <sup>3</sup>	3)		-4 +176	o ⊑ 3)
Ambience <sup>2) 4)</sup>		-20 +80 °C <sup>3</sup>			-4 +176	
		-30 +105 °C			-4 +176	
■ Storage <sup>2)</sup>	2) Alexandra di	<sup>2)</sup> Also complies with EN 50178, Tab. 7, Operation (C) 4K4H, Storag				
					ectrical connectio	
	examination	1	30 +105 °C / ·	-22 +221 °F	and table page 5	
Rated temperature range		0 +80 °C			+32 +176	D F
Temperature coefficients within						
rated temperature range						
Mean TC of zero	% of span	≤ 0.2 / 10 K				
Mean TC of range	% of span % of span	≤ 0.2 / 10 K ≤ 0.2 / 10 K				
■ Mean TC of range CE-conformity		≤ 0.2 / 10 K				
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> </ul>		≤ 0.2 / 10 K 97/23/EC				
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> </ul>		≤ 0.2 / 10 K 97/23/EC 2004/108/EC,	EN 61 326 Emiss	sion (Group 1, (	Class B) and	
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> </ul>		≤ 0.2 / 10 K 97/23/EC 2004/108/EC,	EN 61 326 Emiss Istrial locations)	sion (Group 1, (	Class B) and	
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially</li> </ul>		≤ 0.2 / 10 K 97/23/EC 2004/108/EC,		sion (Group 1, (	Class B) and	
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> </ul>		≤ 0.2 / 10 K 97/23/EC 2004/108/EC, Immunity (indu 94/9/EC		sion (Group 1, (	Class B) and	
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> </ul>	% of span	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4</sup>) 1/2</li> </ul>	istrial locations)		Class B) and	
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> </ul>	% of span	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4</sup>) 1/2</li> <li>Ex ia I/II C T4,</li> </ul>	estrial locations) 2G, 2G, M1, M2 Ex ia I/II C T5, E	x ia I/II C T6	Class B) and	nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> </ul>	<ul> <li>% of span</li> <li>ATEX</li> <li>4) Read the op</li> </ul>	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4</sup>) 1/2</li> <li>Ex ia I/II C T4,</li> </ul>	estrial locations) 2G, 2G, M1, M2 Ex ia I/II C T5, Ei s and <b>safety-rel</b>	x ia I/II C T6 evant data in t		nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> <li>Ignition protection type</li> </ul>	% of span         %         ATEX         4) Read the op certificate in	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4</sup>) 1/2</li> <li>Ex ia I/II C T4,</li> <li>erating condition</li> </ul>	estrial locations) 2G, 2G, M1, M2 Ex ia I/II C T5, E is and <b>safety-rel</b> 04 ATEX E 068 >	x ia I/II C T6 evant data in t		nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> <li>Ignition protection type</li> <li>Ex-protection</li> </ul>	<ul> <li>% of span</li> <li>ATEX</li> <li>4) Read the op</li> </ul>	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4)</sup> 1/2</li> <li>Ex ia I/II C T4,</li> <li>erating condition</li> <li>any case (BVS)</li> <li>Class I, II and I</li> </ul>	estrial locations) 2G, 2G, M1, M2 Ex ia I/II C T5, E is and <b>safety-rel</b> 04 ATEX E 068 >	x ia I/II C T6 levant data in t <)		nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> <li>Ignition protection type</li> <li>Ex-protection</li> </ul>	% of span         %         ATEX         4) Read the op certificate in	≤ 0.2 / 10 K     97/23/EC     2004/108/EC,     Immunity (indu     94/9/EC     Category <sup>4)</sup> 1/2     Ex ia I/II C T4, erating condition     any case (BVS     Class I, II and I     Intrinsic safe C	2G, 2G, M1, M2 Ex ia I/II C T5, E s and <b>safety-rel</b> 04 ATEX E 068 > III Class I, II, III Divis	x ia I/II C T6 l <b>evant data in</b> t K) ion 1,	the EC-type exar	nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> <li>Ignition protection type</li> </ul>	% of span         ATEX         4) Read the op certificate in FM, CSA	≤ 0.2 / 10 K     97/23/EC     2004/108/EC,     Immunity (indu     94/9/EC     Category <sup>4)</sup> 1/2     Ex ia I/II C T4, erating condition     any case (BVS     Class I, II and I     Intrinsic safe C     Group A, B, C,	estrial locations) 2G, 2G, M1, M2 Ex ia I/II C T5, E is and <b>safety-rel</b> 04 ATEX E 068 >	x ia I/II C T6 l <b>evant data in</b> t K) ion 1,	the EC-type exar	nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially explosive atmospheres</li> <li>Ex-protection</li> <li>Ignition protection type</li> <li>HF-immunity</li> </ul>	<ul> <li>% of span</li> <li>ATEX</li> <li><sup>4)</sup> Read the op certificate in FM, CSA</li> <li>V/m</li> </ul>	≤ 0.2 / 10 K     97/23/EC     2004/108/EC,     Immunity (indu     94/9/EC     Category <sup>4)</sup> 1/2     Ex ia I/II C T4, erating condition     any case (BVS     Class I, II and I     Intrinsic safe C     Group A, B, C,     10	2G, 2G, M1, M2 Ex ia I/II C T5, E s and <b>safety-rel</b> 04 ATEX E 068 > III Class I, II, III Divis	x ia I/II C T6 l <b>evant data in</b> t K) ion 1,	the EC-type exar	nination
<ul> <li>Mean TC of range</li> <li>CE-conformity</li> <li>Pressure equipment directive</li> <li>EMC directive</li> <li>Directive ATEX of equipment intended for use in potentially</li> </ul>	% of span         ATEX         4) Read the op certificate in FM, CSA	<ul> <li>≤ 0.2 / 10 K</li> <li>97/23/EC</li> <li>2004/108/EC,</li> <li>Immunity (indu</li> <li>94/9/EC</li> <li>Category <sup>4</sup>) 1/2</li> <li>Ex ia I/II C T4,</li> <li>erating condition</li> <li>any case (BVS)</li> <li>Class I, II and I</li> <li>Intrinsic safe C</li> <li>Group A, B, C,</li> <li>10</li> <li>2</li> </ul>	2G, 2G, M1, M2 Ex ia I/II C T5, E s and <b>safety-rel</b> 04 ATEX E 068 > III Class I, II, III Divis	x ia I/II C T6 levant data in t K) ion 1, Class I, Zone 0 /	the EC-type exar	nination

Specifications		Model IS-20-H
Wiring protection		
Short-circuit proofness		Sig+ towards UB-
Reverse polarity protection		UB+ towards UB-
Weight		
» Model IS-20-H	kg	Approx. 0.3
» Model IS-20-H with fieldcase	kg	Approx. 0.45

 $\{\,\}$  Items in curved brackets are optional extras for additional price.

# Output signal and admissible load Model IS-20-H



Output current (2-wire)					
4 20 mA:	$R_A \le (U_B - 10 \text{ V}) / 0.02 \text{ A}$				

#### Model IS-20-H with fieldcase



## Output current (2-wire) 4 ... 20 mA: R<sub>A</sub> ≤ (U<sub>B</sub> – 11 V) / 0.02 A

#### Relation of medium temperature to ambient temperature



#### Calculation of operation temperatur:

		or operation temperature						
T <sub>B</sub> = T	$T_B = Tmed - (T_{med} - T_{amb}) \times 0.34$							
Т <sub>В</sub>	=	Operation temperature of transmitter						
T <sub>med</sub>	=	Max. temperature of process medium						
Tamb	=	Max. temperature of ambience						

#### Max. permitted temperature of ambience:

 $T_{amb} = T_{med} + (T_B - T_{med}) / 0.34$ 

#### **Dimensions in mm**

Permissible temperature ranges depending on electrical connections; see table page 5.

#### **Electrical connections**

#### IS-20-H



For installation and safety instructions see the operating instructions for this product. For tapped holes and welding sockets please see Technical Information IN 00.14 for download at www.wika.de -Service

(F250-C)

\*) Connectors are not included in delivery.
\*\*) The respective values for your mounting position please find in the documentation of your high-pressure equipment supplier.

# Permissible temperature ranges depending on electrical connections

Electrical connections	Order- code	Category	Ambience-/ Medium temperature range		
DIN 175301-803 A L-Connector	A4	1/2 G (IIC)	-40 +60 °C (T6) -40 +80 °C (T5) -40 +105 °C (T4)	-40 +140 °F (T6) -40 +176 °F (T5) -40 +221 °F (T4)	
		M1	-40 +105 °C	-40 +105 °F	
M 12x1 Circular connector	M4	1/2 G (IIC)	-25 +60 °C (T6) -25 +80 °C (T5) -25 +90 °C (T4)	-13 +140 °F (T6) -13 +176 °F (T5) -13 +194 °F (T4)	
		M1	-25 +90 °C	-13 +194 °F	
Flying leads	DL	1/2 G (IIC)	-20 +60 °C (T6) -20 +80 °C (T5) -20 +80 °C (T4)	-4 +140 °F (T6) -4 +176 °F (T5) -4 +176 °F (T4)	
		M1	-20 +60 °C	-4 +140 °F	
Fieldcase	FH, FC	1/2 G (IIC)	-50 +60 °C (T6) -50 +80 °C (T5) -50 +105 °C (T4	-58 +140 °F (T6) -58 +176 °F (T5) -58 +221 °F (T4	
		M1	-50 +105 °C (T4)	-58 +221 °F (T4)	

# Wiring details

Wiring details							
	L-connector DIN 175301-803 A	Circular connector M12x1, 4-pin	Flying leads, 1.5 m	Field case (with internal s	spring clip term	inals)	
					00000 1 <b>2345</b>		
2-wire	UB = 1 0V = 2	UB = 1 0V = 3	UB = brown 0V = green	UB = 1	0V = 2	Test+ = 3	
			screen / case	Test- = 4	screen = 5		
Wire gauge	up to max.1.5 mm <sup>2</sup>	-	0.5 mm <sup>2</sup> (AWG 20)				
Cable diameter	6-8 mm ship approval: 10-14 mm	-	6.8 mm (Order code: DL)	7-13 mm			
Ingress protection per IEC 60 529	IP 65	IP 67	IP 67	IP 67			
	The ingress protection classes specified only apply while the pressure transmitter is connected with female connectors that provide the corresponding ingress protection.						

## Hazardous areas (zone classification according to ATEX)

# Group II: Electrical equipment for use in all areas (except mines) which are endangered by an explosive atmosphere.

Zone	Category	Occurrence of explosive atmosphere	
Zone 0	Category 1G (gas)	Continuous	
Mounting to zone 0	Category 1/2 G	Continuous	
Zone 1	Category 2G	Intermittent	
Zone 2	Category 3G	Hazard under abnormal conditions	

#### Group I: Electrical equipment for use in mines (hazard due to mine gas)

Zone	Category	Requirements		
	Category M 1	Very high degree of safety		
	Category M 2	High degree of safety (instruments have to be turned off if they are exposed to an explosive atmosphere)		

## Hazardous areas (ATEX in comparison with FM, CSA)

		ATEX	FM / CSA	
		Group	Class	Group
	Gases and Vapours	IIA / IIB / IIC	1	
Above ground	Dusts		11	A/B/C/D/E/F/G
	Fasern		III	A/B/C/D/E/F/G
Mining	Gas / Dusts	1	ID / IIF	

	Flammable material present continuously	Flammable material present intermittently	Flammable material normally not present
ATEX	Zone 0	Zone 1	Zone 2
FM /CSA	Zone 0	Zone 1	Zone 2
	Division 1		Division 2
FM (NEC505)	Zone 0	Zone 1	Zone 2

## **Further information**

You can obtain further information (data sheets, instructions, etc.) via our internet address www.wika.de

Specifications and dimensions given in this leaflet represent the state of engineering at the time of printing. Modifications may take place and materials specified may be replaced by others without prior notice.

Page 6 of 6

WIKA Data Sheet PE 81.51 · 09/2008



WIKA Alexander Wiegand GmbH & Co. KG Alexander-Wiegand-Straße 30 63911 Klingenberg/Germany Tel. +49 / (0) 9372/132-0 Fax +49 / (0) 9372/132-406 E-mail info@wika.de www.wika.de