

# Pressure transmitter COMPACT ECOnomic for general application, Type series CA1100



# Features

- Digital pressure transmitter
- Case and wetted parts of stainless steel, degree of protection IP 65
- Measuring ranges
  - 0...1 bar up to 0...1000 bar
  - -1...0 bar up to -1...15 bar
  - Output signal 4...20 mA, 2-wire technology
- Accuracy ≤ 0.5 %
- Easy zero point correction using a magnet
- Media temperature -20...120 °C

#### Options

- Approvals/Certificates
  - Certificate of measuring equipment for Russian Federation
- Output signal (invers) 20...4 mA
- Various process connections
- Further electrical connections
- Accuracy ≤ 0.3%

#### Application

The pressure transmitter COMPACT ECOnomic is suitable for measuring the relative and absolute pressure of gases, vapors and liquids.

Thin film sensor

# **Technical data**

Machinery construction

General process technology

**Application area** 

Chemical and petrochemical industry

Constructional design / case		Process connection		
Design:	Compact case with outstanding protection against moisture	Design:	<ul> <li>G 1/2 B per EN 837-1</li> <li>G 1/4 B per EN 837-1</li> </ul>	
Material:	Stainless steel matno. 1.4301 (304)		<ul> <li>G 1/4 A per DIN EN ISO 1179-2 (DIN 3852-11) model E</li> </ul>	
Degree of protection per EN 60529:	IP 65		<ul> <li>G 1/2 A per DIN EN ISO 1179-2 (DIN 3852-11) model E</li> <li>1/4" NPT per EN 837-1</li> </ul>	
Pressure compensation:	Ventilation via electrical connection		<ul> <li>1/2" NPT per EN 837-1</li> <li>M20 x 1.5</li> </ul>	
Electrical	<ul> <li>Circular connector M12x1 (4 pin)</li> </ul>			
connection Weight:	<ul> <li>Right-angle plug per DIN EN 175 301- 803-A (DIN 43650 model A)</li> <li>Approx. 0.15 kg</li> </ul>	Material wetted parts		
		Process connection:	Stainless steel matno. 1.4301 (304), 1.4542 (630) at nominal range 1000 bar	
		Diaphragm:	Stainless steel matno. 1.4542 (630)	
		Measuring sy	rstem	

Sensor:

#### Nominal range

Nominal range	Standard measuring		Measuring spans		Overload limits	Vacuum tight
[bar]	range* [b		min. [bar]	max. [bar]	[bar]	ugin
3	01 01.6 02.5	-10 -10.6 - 11,5 -13	1	3	6	
10	04 06 010	-15 -19	3	12	20	
50	016 025 040	-115	12.5	50	100	-1 bar
200	060 0100 0160		50	200	400	
1000	0250 0400 0600 01000		200	1000	1200	

\* different measuring ranges upon request

### Accuracy

<u>General</u>	
Limit point setting:	per DIN 16086
Reference conditions:	per DIN EN 60770-1
Calibration position:	vertical mounting position
Accuracy: (Lin./Hyst./Rep.)	<ul> <li>≤ 0.5 % of adjusted measuring range optional:</li> <li>≤ 0.3 % of adjusted measuring range</li> </ul>
Long term drift:	≤ 0.1 % / year of nominal range

Temperature	range 050 °C:	
influence:	≤ 0.2 % of nominal range	
	range -200 and 5080 °C:	
	$\leq$ 0.3 % of nominal range	

#### Output

Signal:	420 mA (204 mA), 2-wire technology
Damping:	30 ms
Measuring rate:	250 Hz
Current range:	3.723 mA
Resolution:	0.04 % of nominal range
Load, R:	$R \le (U-10V)/0.02 A [\Omega]$ U = supply voltage

#### Supply voltage

Functional	1030 V DC
range:	

#### **Temperature ranges**

Ambient:	-2085 °C	
Media:	-20120 °C *	
Storage:	-4080 °C	
$^{\ast}$ at a maximal ambient temperature of $~40\ ^{\circ}$ C		

Extended temperature ranges upon request

#### Tests and certificates

EMC: EMC directives 2014/30/EU

EAC declaration upon request

÷ () 3]

 Certificate of measuring equipment for Russian Federation

## **Connection diagram**





Do not wire terminal 2 + 4



- (-)

(+)

right-angle plug

Do not wire terminals 3 + 4



All dimensions are in minimeters

## Zero point correction

The zero point can be set easily with a magnet within  $\pm$  10% of the nominal range.

To correct the zero point, hold a permanent magnet – a pin board magnet, for example – at the position marked on the pressure transmitter (i.e. the letter in a circle) for 1/2 to 2 1/2 minutes after the power has been switched on. To correct the zero point, atmospheric pressure has to be applied. Offsets for previously set values for initial and ultimate pressures will be corrected automatically by the device. A magnetic field applied outside of this time period has no effect on the setting. The power must be switched off and on before the zero point can be set again.



#### Pressure transmitter COMPACT ECO for general application Type series CA1100

	ype series CATTOO			
	Order details COMPACT ECO CA1100			
CA1100	Pressure transmitter COMP	ACT ECO for general application		
A3053		01		
A3054		01.6		
A3055		02.5		
A3056		04		
A3057		06		
A3058		010		
A3059		016		
A3060		025		
A3061		040		
A3062		060		
A3063		0100		
A3064	Measuring range	0160		
A3065	(bar)	0250		
A3066		0400		
A3068		0600		
A3070		01000 <sup>1</sup>		
A3086		-10		
A3087		-10.6		
A3088	_	-11.5		
A3089	_	-13		
A3090		-15		
A3091		-19		
A3092		-115		
A9999	_	different measuring ranges upon request		
H1	Output signal	420 mA, 2-wire technology (standard)		
H7	<ul> <li>Output signal</li> </ul>	204 mA, 2-wire technology		
T110		right-angle plug per DIN EN 175 301-803-A (DIN 43650, model A)		
T120	Electrical connection	circular connector M12x1 (4 pin)		
K10		G 1/2 B, EN 837-1		
K12		G 1/4 B, EN 837-1		
K20	-	G 1/2 A, DIN EN ISO 1179-2 (DIN 3852-11) model E		
K24	Process connection internal diaphragm	G 1/4 A, DIN EN ISO 1179-2 (DIN 3852-11) model E		
K30		1/2" NPT, EN 837-1		
K32		1/4" NPT, EN 837-1		
K40	-	M20 x 1.5		
K32		1/4" NPT, EN 837-1		

Additional features (to be indicated if required)			
Q3	Accuracy	≤ 0,3 %	
W2673	certificate of measuring equipment for Russian Federation		

#### Order code (example): CA1100 - A1054 - H1 - T120 - ...

 $^{\rm 1}$  only for process connections K10 and K24